

# **Certificate of Smoke Alarm/ Carbon Monoxide Alarm/ Portable Fire Extinguisher Compliance (CSACMAPFEC) for One and Two Family Dwellings in Bernardsville**

**Effective April 1, 2018**

## **New Jersey State Requirements for compliance require...**

Prior to the sale or lease of any residential structure or any change in occupancy for residential purposes, the owner shall obtain a **CSACMAPFEC** with the Bernardsville Borough Fire Official.

### **● Smoke Alarms**

- Minimum of one on each level is required. Including the basement.
- If the smoke alarms are hardwired interconnected every Smoke Alarm in the house **MUST** go off when one is tested. Battery operated alarms shall not replace any interconnected alarm systems.
- All Smoke Alarms are required by the State to be replaced every ten (10) years; and to be of the ten (10) year sealed battery type.
- All Smoke Alarms must be maintained as approved at the time of construction or renovation.

### **● Carbon Monoxide Alarms**

- Outside each bedroom(s) in hallway within 10' of each bedroom doorway.
- In a one bedroom condo place inside bedroom. All Carbon Monoxide alarms are required to be changed every **ten (10) years**.
- Carbon Monoxide Alarms are permitted to be battery operated, hard-wired or the plug in type.

### **● Portable Fire Extinguishers**

- **SIZE:** Portable Fire Extinguishers are required on resale and rental of all residential dwellings. The requirement is that the Fire Extinguisher is a 2A/10 BC dry chemical UL rated and does **NOT** exceed 10 lbs.

Extinguisher is a 2A/10 BC dry chemical UL rated and does NOT exceed 10 lbs.

- o **LOCATION:** Visible mounted within 10 feet of kitchen. Height not to exceed 5' and cannot be behind a door or inside a cabinet. Fire Extinguisher must be in a fully charged condition and the operating instructions must be clearly visible.
- o **All Fire Extinguishers** must be purchased within the last 12 months of the inspection and have the receipt and instruction manual present at the time of the inspection. Or the Fire Extinguisher shall be serviced and tagged by a certified Division of Fire Safety contractor within the past 12 months.

Fire safety-licensed alarm contractors:

- Knox Security – 908-850-8855
- Consolidated Fire Protection – 973-361-0640
- Ultrasafe Security – 973-697-7677
- Absolute Protective System – 732-287-4500
- City Fire Equipment – 973-560-1600
- Confires – 908-912-3061
- Alarms Plus – 973-927-1500